


COPY OF LETTER

Correspondence No.....

DEPARTMENT OF HEALTH
GENERAL HEALTH BRANCH
295 QUEEN STREET
MELBOURNE, VIC. 3000

ATG:VM

15th December, 1971.



Mr. John D. Fowler,
Odessa Promotions,
1 Kogin Street,
MT. ELIZA. 3930

Re:- Proposed Sunbury Summer Happening - Digger's Rest,
Temporary Public Building.

Dear Sir,

I have to inform you that the plans and specifications of the abovementioned proposed temporary public building have now been approved by the Commission of Public Health in accordance with the provisions of the Health Act 1958. No amendment of or departure from this approved plan and specification may be made without the consent in writing of the Commission of Public Health.

The Commission has noted that you have obtained the approval of the Shire of Bulla to the use of Crown Allotments A, B and C of Section 16, Parish of Holden at Digger's Rest, for the erection of this temporary public building and you should now submit to the local municipal council a copy of the approved plan and specification. The Commission's approval to the plan and specification is issued subject to the following conditions:-

1. That the scaffolding stage be constructed to the satisfaction of the local Council.
2. That the general public must not be admitted on to the stage.
3. Clearly designate the toilets for the sexes, and erect and superintend same to the satisfaction of the local Council.
4. Provide that the disposal of the waste water, etc., from the showers, hand basins, toilets and urinals be to the satisfaction of the local Council.
5. Electrical:
 - (a) Provide that the electrical installation including all aerial conductors and underground wiring are installed in accordance with Regulations 111, 331 and 332 contained in the 1961 Wiring Regulations of the State Electricity Commission of Victoria.
 - (b) Provide adequate lighting connected to at least two phases of the supply for all sections to be used by the public, including to and at the toilets, switched solely at the switchboard.
 - (c) Install all light fittings at least 6'8" above floor or ground level.
 - (d) Protect in an approved manner any surface mounted T.P.S. or T.R.S. conductors and any fluorescent lights installed less than 8'0" above floor or ground level.


2/cont'd.

5. Electrical: Cont'd.

- (e) Provide that the whole of the electrical installation shall be effectively connected to the earthing system in accordance with the relevant regulations.
- (f) Provide that each generator is positioned in an approved enclosure fitted with a lockable gate.
- (g) Carry out the whole of the work in compliance with the relevant provisions contained in the Public Building Regulations 1952.

The plans and specification submitted with your application have been retained for record purposes.

Yours faithfully,



(A.F. Gardner)
Secretary.

Commission of Public Health.

Copies sent to:-

Shire Secretary, Shire of Bulls, Municipal Offices, Macedon Street, Sunbury. 3429

Electrical Contractor, G/- Odessa Promotions, 1 Kogla Street, Mt. Eliza. 3930

Officer in Charge, Police Station, Digger's Rest. 3427